

VOC Emission Test Certificate

Wednesday 24th July 2024

Supplier: Australian Panels Pty Ltd (2 Wella Way, Somersby, NSW, 2250, AUSTRALIA).
Product Name: Easycraft Panels thickness 9-16 mm – Wall and Ceiling Linings.
Date Tested: 4th July 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Test Data (7 days):

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Easycraft Panels (9-16 mm) Wall and Ceiling Linings
Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.030 mg/m ² /hr

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant