

Certificate of Assessment

Job No.: NK7193

No. 2117

“Copyright CSIRO 2014 ©”
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Easycraft Australia Pty Ltd
140 North Road
WYNNUM WEST QLD 4178
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 11258.

SAMPLE

IDENTIFICATION: Easycraft MDF MR E0 9mm Primed

DESCRIPTION OF

SAMPLE: The sponsor described the tested specimen as medium density fibreboard (MDF) primed on the exposed face. The specimen was coated with Akzo Nobel Easycraft Cream primer.

Nominal thickness of primer:	83-µm to 107-µm per coat
Nominal total thickness:	9.5-mm
Nominal total mass:	6.9 kg/m ²
Nominal total density:	760 kg/m ³
Colour:	cream

SAMPLE

CLASSIFICATION: Group Number: Group 3
(In accordance with Specification A2.4 of the Building Code of Australia.)

Average specific extinction area: 38.4 m²/kg
(Refer to Specification C1.10 section 4(c) of the Building Code of Australia.)

Testing Officer: Heherson Alarde Date of Test: 12 September 2014

Issued on the 17th day of September 2014 without alterations or additions.



Brett Roddy
Team Leader, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025

CSIRO INFRASTRUCTURE TECHNOLOGIES

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555 www.csiro.au

