

## Test report No. 19848A

### Sponsor

UNILIN BVBA DIVISION PANELS  
Ingelmunstersteenweg 229  
8780-Oostrozebeke  
BELGIUM

### Construction product and trade names

Fibrалux FR (former trade name Firax) ; Flameblock™

### Nature of the test

Full-scale room test for surface products according to ISO 9705 – 1<sup>st</sup> edition  
1993 and ISO 9705-1:2016

### Summary of the results

FIGRA <sub>RC</sub> (kW/s)	0,99
THR <sub>RC</sub> (MJ)	64,2
SMOGR <sub>RC</sub> (m <sup>2</sup> /s <sup>2</sup> )	179,88
TSP <sub>RC</sub> (m <sup>2</sup> )	1215
Time to flash over (s)	705

PREPARED BY

APPROVED BY

**This report consists of 19 pages including 1 annex**

This document is the original version of this test report and is written in English.

This report may be used only literally and completely for publications. - For publications of certain texts, in which this report is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.

## 1. TEST MATERIAL

The firm UNILIN BVBA Division Panels, provided the laboratory with Fibromax FR MDF-boards on the 24<sup>th</sup> of July 2019, intended for a full-scale room test for surface products. The laboratory supervised with the specimen fabrication.

### Sampling details:

Sampling by : Unilin division Panels, Koen Nel  
 Sampling date : 14<sup>th</sup> of June 2019  
 Sample ID : 4190429  
 Production place : Unilin division Panels, Vielsalm  
 Rue de la Forêt, 6690 Vielsalm  
 Production line : MDF line  
 Production date : 25<sup>th</sup> of April 2019  
 Identification within the quality system : PO 4144498

### Description of the material:

*This description is based on information given by the sponsor.*

	Nominal value	Measured value
<b>WALL COVERING</b>		
Material	MDF panel, type MDF.LA (EN622-5)	
Trade names	Fibralux FR (former trade name Firax) ; FlameblockTM	
Manufacturer / Supplier	UNILIN BVBA Division Panels	
Colour	Brown-red	
Thickness (mm)	12,0	12,2
Density (kg/m <sup>3</sup> )	730	755
Flame retardants	Yes	(1)
Fixing method	Mechanically directly to the wall	
Type and amount of fixing	Chipboard screws #6x60mm 15 per panel Screw hole centres 50mm from side of panel Drawing see annex 1	
Reaction to fire according to EN 13501-1	B-s1, d0	

(1) Not verifiable

## **2. DESCRIPTION OF THE TEST METHOD**

The fire test is carried out according to the ISO 9705:1993.

The ISO 9705:1993 prescribes the following procedure:

- ✓ -2 – 0 minutes: Start registering data from the test
- ✓ 0 – 10 minutes: heat output level of the burner: 100 kW
- ✓ 10 – 20 minutes: heat output level of the burner: 300 kW
- ✓ 20 minutes: extinction of the burner

## **3 TEST CONDITIONS**

Test date: 01/07/2019

Ambient temperature: 22,5 °C

Ambient pressure: 101500 Pa

Humidity: 53%

## **4. CALIBRATION RESULTS**

Latest calibration date : 01/04/2019

Calibration results : see annex 3

## 4 OBSERVATIONS AND MEASUREMENTS DURING THE TEST

### 4.1 visual observations

Time (min:sec)	Observation
-02:00	Start of data acquisition system
00:01	Ignition of the burner to the level of 100kW
02:55	Development of smoke
09:59	Burner level increased to 300 kW
12:10	Spread of flames across the ceiling and the walls, both occurred at the same moment (*)
12:15	Ceiling ignites
12:30	Wall covering ignites
13:00	Flash over, based on visual observations
13:37	First flames through the door opening
13:58	Mechanical failure of the test specimen: MDF-board which is part of the ceiling falls apart in back left corner
16:23	Flaming droplets
18:35	Test stop

(\*) Concerning the walls, spread of flames is considered as the moment the flames spread in the area 0,5 m above floor level and at a distance of minimum 1,2m from the burner.

**Time at which the sum of the Heat release rate from the ignition source and the product reaches 1 MW: 13:45\*\***

(\*\*) This time, is the moment in time defined as flash-over, according to ISO9705:1993 and 2016.

Pictures of the test: see annex 2

### 4.2 Volume flow and temperature in exhaust duct

Graphs see Annex 4

#### 4.3 Rate of heat release and smoke production

<b>FIGRA (kW/s)</b>	0,99
<i>HRR ignition source at time of flash-over (kW)</i>	300
<i>Flash-over (sec)</i>	705
<b>THR (MJ)</b>	64,2
<b>SMOGRA (m<sup>2</sup>/s<sup>2</sup>)</b>	179,88
<b>Maximum SPR (m<sup>2</sup>/s<sup>2</sup>)</b>	15,60
<b>TSP (m<sup>2</sup>)</b>	1215

Calculations according to § 6.2 of the SP report 1998:11 "Results and Analysis from Fire Tests of Building Products in ISO 9705, the Room/Corner Test – The SBI Research Programme" by *B. Sundström, P. van Hees and P. Thureson*.

Graphs in support of the results: see Annex 5

#### **5. REMARKS**

The following deviation to the standard is made: None

The test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

## 6. GROUP ASSESSMENT

This report assesses the fire hazard properties assigned to the product '**Fibralux FR (former trade name Firax); Flameblock™**' in accordance with the NCC 2015 Building Code of Australia - Volume One and the New Zealand Building Code (NZBC) Clause C3.4(a) and defines the group number in accordance the procedures given in with the draft standard AS 5637.1:2015 (Determination of fire hazard properties - Part 1: Wall and ceiling linings. The product '**Fibralux FR (former trade name Firax); Flameblock™**' in relation to its reaction to fire behavior for wall and ceiling linings is assessed as:

**Flash over at 705s**


**Australian Group Number according to AS 5637.1:2015**


Fire behavior Group number
2

**Criteria Australian Group Numbers according to AS 5637.1:2015, based on AS ISO 9705:2003 (identical to ISO 9705:1993)**


Group 1	does not reach flashover when exposed to 100kW for 600s followed by exposure to 300 kW for 600s.
Group 2	reaches flashover following exposure to 300kW within 600s after not reaching flashover when exposed to 100kW for 600s.
Group 3	reaches flashover in more than 120s but within 600s when exposed to 100kW.
Group 4	reaches flashover within 120s when exposed to 100kW.


**Annex 1: Mounting and fixing details**











**Annex 2 Photos of the specimen**

*Build-up before the test:*



*During the test:*






*After the test:*




### Annex 3: Calibration results

#### Step calibration





#### Methanol calibration




## Annex 4

Volume flow ( $\text{m}^3/\text{s}^2$ ) and temperature ( $^{\circ}\text{K}$ ) in exhaust duct




## Annex 5: Test results

### 5.1 Gas concentrations in function of time




### 5.2 Heat flux at floor level






5.2 Time/smoke production rate at actual duct flow temperature in function of time:



5.4 Total smoke production

$TSP(t) = \sum SPR(t) \cdot 3s$  total smoke production during the time interval 0->t with t being the time at flash-over or the end of the test.



## 5.5 SMOGRA

SMOGRA = 10.000 \* PeakSPR<sub>smooth</sub>/t , where


$$SPR_{smooth}(t) = \frac{SPR(t - 30\text{ s}) + SPR(t - 27\text{ s}) + \dots + SPR(t + 27\text{ s}) + SPR(t + 30\text{ s})}{t}$$

Peak value: at 11,98 m<sup>2</sup>/s


Correlates with a peak after 789 seconds

SMOGRA = 10.000 \* (11,98 m<sup>2</sup>/s) / 666 s = 179,88 m<sup>2</sup>/s<sup>2</sup>

Time (sec)	SPRsmooth (m <sup>2</sup> /s)
657	11,11
660	11,52
663	11,84
666	11,98
669	11,91
672	11,82
675	11,68



## 5.6 Heat release



## 5.7 FIGRA

$FIGRA = \frac{PeakHRR_{product}}{t}$ , where  $PeakHRR_{product}$  is the maximum HRR(kW)

Flash over occurred after the 10 minute mark, during the time the HRR of the ignition source was at a level of 300kW.

